

Malaysia LNG – Emergency Power G-4050



(Above) 3412 Caterpillar engine view inside the enclosure



(Above) Preparation for FAT testing in workshop.

Customer:	Petra Resources.
Application:	Emergency power generation for LNG plant in Malaysia
Year:	2005
Delivery:	1 x 3412 DIT Caterpillar diesel engine packaged with Leroy Somer generator in sound attenuated enclosure 85 dB(A)
Power Rating:	1 x 400 EkW (500 kVA), 415V, 50Hz at 1500 rpm
Remarks:	In compliance with Petronas specifications Delivery includes 12 hr fuel tank, local & remote control & protection panels